

Geothermal Case Study

Lieffring Residence—Erdenheim: 2007-2010
Deer River, MN
7 Ton ColdClimate Hydronic Heat/Cool GSHP Application

PRESENTER:
Mark Sakry, CGD
Northern GroundSource Inc.
www.NorthernGroundSource.com




Lieffring Erdenheim—Deer River, MN

Old Faithful Geyser




"Hot Rocks" Power




High Grade Geothermal Energy

"Solar" Geothermal

GeoExchange Systems




Low Grade Geothermal Energy



Geothermal Heat Pump System

Load to Source: Sustainability Factor



GSHP requires only 9 kWh_T from the source to provide 10 kWh_T to the building since they can provide a COP of 3.7


**Water to Air GHP
(Forced Air)**



**Water to Water GHP
(Hydronic)**



Ground Source Heat Pumps



Many GHEX/Earth Loop Options
(Who decides?... Who designs?)

Supply Side (GSHP)


- Ground Heat Exchanger (GHEX)
- Ground Source Heat Pump (GSHP or GHP)
- Loop Pump or Flow Center
- Some Peripheral and Auxiliary Components (incl. Controls)

Delivery Side (HVAC)

- Duct System (incl. Air Exchanger)
- Radiant Floor Tubing, Manifolds, Zone Pumps and Controls
- Radiant Baseboards, Panels, Radiators
- Plumbing/Piping Delivery Systems


The "geothermal system" is generally assigned to the "supply" side of heating/cooling functions.

**High Temp @
50,000 BTUH!**



130°F - 180°F


**Low Temp @
50,000 BTUH!**




85°F - 115°F

High Temp *versus* Low Temp?

~~High Temp @~~
50,000 BTUH!




Low Temp @
50,000 BTUH!



GENERAL PREMISE: The Lower the
Temperature—the Higher the Efficiency!



Consider that GSHP installation costs and benefits are *scalable*!



**Consider that GSHP Technology is
Also Highly Adaptable.**

Prepared By:

Northern GroundSource Inc.
858 Stone Lk. Bridge Rd.
Brinson, MN 55602-6032
Phone: (218) 848-2869

Prepared For:

Herb & Diana Liffing
Rooseville, MN 55110

| Approx. Air Changes / Air Infiltration Rate (CF /hr) | Zone Length | Zone Width | Zone Height | Total Co. of Sq. Feet |
|--|----------------|---------------|-------------------|--------------------------|
| 6.2 | 6.2 | 41.36 | 9.00 | 17,332 |
| Approx. Zone Volume in Cubic Feet | 41.36 | 41.36 | 9.00 | 1,322 |
| Approx. Zone Area in Square Feet | 175.04 | | | 1,582 |
| Indoor Dry Bulb Design Temperature | 60 | Degrees F. | ss Window Area: | 125 |
| Outdoor Dry-Bulb Design Temp | -32 | Degrees F. | Less Door Area: | 20 |
| Design Temperature Difference: | 92 | | Actual Wall Area: | 1,428 |

| Structural Element | Structural Element Description | Area (Sq. Ft.) | Element U-Value | Temperature Difference | Total BTUH |
|---------------------------------|---------------------------------------|----------------|------------------|------------------------|------------|
| Above Grade Ext. Wall Info | 2 x 4 (R-12) | | 0.018 | 100 | 0 |
| | 2 x 6 (R-19) | | 0.0502 | 100 | 0 |
| | ICF (R-24) | 1,428 | 0.047 | 100 | 5,960 |
| Window Information | Single Pane | | 0.590 | 100 | 0 |
| | Double Pane | | 0.4051 | 100 | 0 |
| | Deluxe with Storm | | 0.3682 | 100 | 0 |
| | Anderson HP | 125 | 0.280 | 100 | 4,305 |
| Exterior Door Information | Solid-Core Wood | | 0.2525 | 100 | 0 |
| | 1-3/4" 24 ga. Steel | | 0.638 | 100 | 0 |
| | 1-3/4" 18 ga. Steel | | 0.2257 | 100 | 0 |
| | Deluxe with Storm | 20 | 0.3000 | 100 | 600 |
| Roof / Ceiling Information | R-38 | | 0.0207 | 100 | 0 |
| | R-48 | | 0.0244 | 100 | 0 |
| | R-42 | | 0.0233 | 100 | 0 |
| | R-44 | | 0.0223 | 100 | 0 |
| | Other | | 0.0000 | 100 | 0 |
| Above Grade Exposed Floor | 2 x 8 (R-24) | | 0.0401 | 100 | 0 |
| | 2 x 10 (R-28) | | 0.0246 | 100 | 0 |
| | 2 x 12 (R-33) | | 0.0205 | 100 | 0 |
| | Other | | | 100 | 0 |
| Below Grade Structural Elements | Slab on grade | | 0.0628 | 100 | 0 |
| | Structural Element Description | Area (Sq. Ft.) | BTUH Loss Factor | | |
| | Floor | 1,322 | 3.00 | BTUH per Sq. Ft. | 0 |
| | Walls | | 6.00 | BTUH per Sq. Ft. | 0 |
| Air Losses | Air Loss Description | Air CFM | Loss Factor | Temperature Difference | |
| | Infiltration | 50 | 11 | 100 | 5,780 |
| | Ventilation & Make-Up | 50 | 11 | 100 | 5,600 |
| Deck Loss | Is Deckwork in an Unconditioned Space | Yes / No | U-Value | Subtotal | 28,424 |
| | | No | 0.00 | 28,424 | 0 |

(*) Indicates inside and outside air film is calculated in u-value

(U-value = 1/R-value = BTUH/Sq. Ft. / degree F. Td)

(Air loss factor = BTUH / CFM / degree F. Td)

Total Heat Loss: 28,424

850 - 1000 CFM

70,150 BTUH

Prepared By:

Northern GroundSource Inc.
858 Stone Lk. Bridge Rd.
Brinson, MN 55602-6032
Phone: (218) 848-2869

Prepared For:

Herb & Diana Liffing
Rooseville, MN 55110

| Approx. Air Changes / Air Infiltration Rate (CF /hr) | Zone Length | Zone Width | Zone Height | Total Co. of Sq. Feet |
|--|----------------|---------------|-------------------|--------------------------|
| 6.2 | 6.2 | 41.36 | 9.00 | 18,037 |
| Approx. Zone Volume in Cubic Feet | 41.36 | 41.36 | 9.00 | 1,322 |
| Approx. Zone Area in Square Feet | 175.04 | | | 1,641 |
| Indoor Dry Bulb Design Temperature | 60 | Degrees F. | ss Window Area: | 337 |
| Outdoor Dry-Bulb Design Temp | -32 | Degrees F. | Less Door Area: | 73 |
| Design Temperature Difference: | 92 | | Actual Wall Area: | 1,171 |

| Structural Element | Structural Element Description | Area (Sq. Ft.) | Element U-Value | Temperature Difference | Total BTUH |
|---------------------------------|---------------------------------------|----------------|------------------|------------------------|------------|
| Above Grade Ext. Wall Info | 2 x 4 (R-12) | | 0.018 | 100 | 0 |
| | 2 x 6 (R-19) | | 0.0602 | 100 | 0 |
| | ICF (R-24) | 1,071 | 0.047 | 100 | 4,673 |
| Window Information | Single Pane | | 0.590 | 100 | 0 |
| | Double Pane | | 0.4051 | 100 | 0 |
| | Deluxe with Storm | | 0.3682 | 100 | 0 |
| | Anderson HP | 337 | 0.280 | 100 | 3,207 |
| Exterior Door Information | Solid-Core Wood | | 0.2525 | 100 | 0 |
| | 1-3/4" 24 ga. Steel | | 0.638 | 100 | 0 |
| | 1-3/4" 18 ga. Steel | | 0.2257 | 100 | 0 |
| | Deluxe with Storm | 73 | 0.3000 | 100 | 2,180 |
| Roof / Ceiling Information | R-38 | | 0.0207 | 100 | 0 |
| | R-48 | 1,833 | 0.0244 | 100 | 4,723 |
| | R-42 | | 0.0233 | 100 | 0 |
| | R-44 | | 0.0223 | 100 | 0 |
| | Other | | 0.0000 | 100 | 0 |
| Above Grade Exposed Floor | 2 x 8 (R-24) | | 0.0401 | 100 | 0 |
| | 2 x 10 (R-28) | | 0.0246 | 100 | 0 |
| | 2 x 12 (R-33) | | 0.0205 | 100 | 0 |
| | Other | | | 100 | 0 |
| Below Grade Structural Elements | Slab on grade | | 0.0628 | 100 | 0 |
| | Structural Element Description | Area (Sq. Ft.) | BTUH Loss Factor | | |
| | Floor | | 3.00 | BTUH per Sq. Ft. | 0 |
| | Walls | | 6.00 | BTUH per Sq. Ft. | 0 |
| Air Losses | Air Loss Description | Air CFM | Loss Factor | Temperature Difference | |
| | Infiltration | 63 | 11 | 100 | 8,227 |
| | Ventilation & Make-Up | 60 | 11 | 100 | 7,000 |
| Deck Loss | Is Deckwork in an Unconditioned Space | Yes / No | U-Value | Subtotal | 41,726 |
| | | No | 0.00 | 41,726 | 0 |

(*) Indicates inside and outside air film is calculated in u-value

(U-value = 1/R-value = BTUH/Sq. Ft. / degree F. Td)

(Air loss factor = BTUH / CFM / degree F. Td)

Total Heat Loss: 41,726

800 - 1000 CFM


70,150 BTUH

Heat Loss Calculation = 70,150 BTUH

ERDENHEIM HOUSE: New Construction

- GRAND RAPIDS, MN (Bin Weather Data)
- 70,150 BTUH Heat Loss (@ -30°F OAT)
- 12,168 BTUH Garage (@ 20 BTUH/sq')
- 38,583 BTUH Heat Gain (@ +84°F OAT)
- Space for No More Than 7T Horz. GHEX
- 7 Ton HYD Heat/Cool GSHP System
- Compare to LP Boiler @ \$1.80/Gallon

**Heat Loss w/Garage = 82,318 BTUH
(But Limited to 7T GSHP Due to Space!)**



Hydronic Heat/Cool GSHP System



5 T HYD GSHP w/ 3 T HYD Fan Coil combines radiant floor heating with F/A heating & cooling

GeoSense Data Input

| | | | |
|---|----------|---|-------------|
| Prepared For: | | Prepared By: | |
| Holt & Data Logging 217 Roma Avenue Roseville, MN 55113 707 T GeoSource Ultra w LP | | Northern GroundSource Inc. 1155 Stone Ln, Bridge Rd. Brimley, MN 55002-8032 218-848-2288 | |
| Region (1-6): 2 | | Loop Type: 3.5 T-3.8 Hyd/Loop | |
| City: Grand Rapids, MN | | Loop Type: 3.5 T-3.8 Hyd/Loop | |
| Heating Estimate Design Data | | | |
| Estimated BTU/hr Heat Loss | 82,318 | wt/Designer | 82,318 |
| Heat Pump BTU/hr Output | 64,900 | wt/Designer | 64,900 |
| Number of kW of Aux Ht Suggested | 0 | | |
| Heat Pump C.O.P. | 3.50 | | 3.50 |
| Overall H.P. Heating System C.O.P. | 3.42 | | 3.37 |
| Heating Degree Days | 6,341 | | 6,341 |
| Temperature Difference | 100 | | 100 |
| Correction Factor | 0.80 | | 0.80 |
| KWH Rate for Heat Pump | \$2,055 | | \$2,055 |
| KWH Rate for Aux. Electric Heat | \$2,055 | | \$2,055 |
| KWH Rate for Furnace Heat | \$2,055 | | \$2,055 |
| Conventional Source Table | | | |
| | Units | Efficiency | Cost |
| 1 Electric (Radiant) | KWH | 100% | \$0.075 |
| 2 Electric (Forced Air) | KWH | 100% | \$0.075 |
| 3 Fuel Oil | Gallon | 80% | \$1.300 |
| 4 L.P. Gas | Gallon | 80% | \$1.800 |
| 5 Natural Gas | Therm | 80% | \$1.150 |
| Conventional Source Selection | | | |
| | Heating | | Other |
| Number of Other Energy Sources | 4 | | 1 |
| Other Source Efficiency | 80% | | 100% |
| Other Source Cost or Rate | \$1.350 | | \$0.075 |
| Cooling Estimate Design Data | | | |
| Estimated BTU/hr Heat Gain | 38,903 | Heat Pump | 38,903 |
| Heat Pump A/C BTU/hr Capacity | 45,200 | Conventional | 38,903 |
| Cooling System E.E.R. | 20.5 | Units | 18.5 |
| Cooling Degree Days | 258 | | 258 |
| Temperature Difference | 20 | | 20 |
| Summer or A/C Electric Rate | \$2,055 | | \$2,075 |
| DHW Estimate Demand Data | | | |
| | Quantity | | Units |
| Total Number of People in the Household | 3 | | People |
| Average Number of Gallons per Person per Day | 15 | | Gallons |
| Average Number of Gallons Needed per Day | 45 | | Gallons/Day |
| Expected Average Leaving Water Temperature | 130 | | Degree F. |
| Expected Average Entering Water Temperature | 40 | | Degree F. |
| Average Overall Water Temperature Difference | 85 | | Degree F. |

Northern GroundSource GSHP Design Input

ColdClimate GSHP Capacity to Peak Heating Load

LOAD = 82,318 BTUH

7T GSHP = 64,900 BTUH
@ 30°F EWT / 108°F HYD

SIZING = 78.9%

7 kWh AUX RH Recommended
(14 kWh Modulating RH Boiler)

COP Drops from 3.50 to 3.37

5T HYD Fan Coil for Cooling
(45,200 BTUH Capacity)

Northern GroundSource GSHP Design Input

ColdClimate GSHP Capacity to
Peak Heating Load

LOAD = 82,318 BTUH


7T GSHP = 64,900 BTUH
@ 30°F EWT / 108°F HYD

SIZING = 78.9%

7 kWh AUX RH Recommended
(14 kWh Modulating RH Boiler)

COP Drops from 3.50 to 3.37

5T HYD Fan Coil for Cooling
(45,200 BTUH Capacity)



Estimated Annual Operating Costs

For Herb & Diana Liefkring

7T HYD HEAT/COOL GSHP SYSTEM

| Estimated Energy Consumption | | | Heating | | Cooling | DHW | Estimated Annual Totals | |
|-------------------------------------|--------------------------|------------|------------|-----------|---------|-----------|-------------------------|-----------|
| | | | w/o | w/Desuper | | w/Desuper | w/o Desuper | w/Desuper |
| ECONAR GeoSource Heat Pump | Kwh/yr | 12,722 | 12,540 | 585 | 713 | 13,307 | 13,830 | |
| Auxiliary Ht and Electric Water Htr | Kwh/yr | 1,046 | 1,682 | | 1,071 | 1,046 | 2,753 | |
| Other Fuel Source | 1. Electric (Radiant) | Kwh/yr | 14,222 kWh | | 1,199 | 3,919 | 3,919 | |
| | 2. Electric (Forced Air) | Kwh/yr | | | | | 1,199 | |
| | 3. Fuel Oil | Gallons/yr | | | | | | |
| | 4. LP Gas | Gallons/yr | 1,889 | 1,889 | | | | |
| | 5. Natural Gas | Therms/yr | | | | | | |

16,591 kWh

| Estimated Operating Costs | | | Heating | | Cooling | DHW | Estimated Annual Totals | |
|-------------------------------------|----------------------------|----------|------------|-----------|----------|------------|-------------------------|-----------|
| | | | w/o | w/Desuper | | w/Desuper | w/o Desuper | w/Desuper |
| ECONAR GeoSource Heat Pump | | \$712.43 | \$702.24 | \$32.76 | \$39.94 | \$745.18 | \$774.95 | |
| Auxiliary Ht and Electric Water Htr | | \$58.55 | \$94.18 | | \$59.95 | \$58.55 | \$154.14 | |
| Other Fuel Source | 1. Electric (Radiant) | | | | \$297.81 | \$297.81 | | |
| | 2. Electric (Forced Air) * | | | \$91.14 | | \$91.14 | | |
| | 3. Fuel Oil * | | | | | | | |
| | 4. LP Gas * | | \$3,504.63 | | | \$3,504.63 | | |
| | 5. Natural Gas * | | | | | | | |

| Estimated Cost Savings | | | Heating | | Cooling | DHW | Estimated Annual Totals | |
|---------------------------------------|--|-------------------|-------------------|----------------|---------------|-----------------|-------------------------|-------------|
| | | | w/o | w/Desuper | | w/o | w/Desuper | w/o Desuper |
| Conventional Heating, Cooling and DHW | | \$3,504.63 | \$3,504.63 | \$91.14 | \$297.81 | \$3,893.58 | \$3,893.58 | |
| ECONAR GeoSource Heat Pump | | \$770.97 | \$796.43 | \$32.76 | \$297.81 | \$99.90 | \$1,101.55 | |
| Savings Using ECONAR Heat Pump | | \$2,733.66 | \$2,708.21 | \$58.38 | \$0.00 | \$197.91 | \$2,792.04 | |

On a yearly basis, this means the heat pump alone should cover 97.7% of the total space heating load annually. Auxiliary heat shouldn't be needed until the actual outdoor temperature falls to -9 degrees Fahrenheit.

The heat gain to Heat Pump cooling capacity ratio is 1.2. (This ratio should be between 1 and 2)

On a yearly basis, the heat pump alone should also cover 0% of the total DHW water heating load annually.

| w/o | w/Desuper |
|-------|-----------|
| 97.7% | 96.3% |
| -9 | -3 |
| 1.2 | 1.2 |
| 0% | 73% |


96.3% GSHP

* - Includes cost of operating the blower





How Moisture Improves Thermal Conductivity of Soil




At complete dryness the heat flow passes mainly through the grains, but has to bridge the air-filled gaps between the grains around their contact points.



At very low water contents the soil particles are covered by thin absorbed water layers



The thickness of these layers increases with increasing water content. At a certain X_w liquid rings start to form around the contact points between the grains; they show a curved air-water interface.



From this point on the thermal conductivity increases rapidly with increasing X_w , until the rings almost completely fill the original gap. When X_w increases still further the complete pores are filled with water, up to saturation. This is reflected by the slower increase of k with X_w .















June through December 2007

| Date Meter Read | Non-Interruptible Household Power | Dual Fuel Econar Geothermal/Seisco Microboiler | Off Peak Hot Water Heat Marathon | Total |
|-------------------|-----------------------------------|--|----------------------------------|--------------|
| July 12, 2007 | 55 | | | 55 |
| August 11, 2007 | 122 | | | 122 |
| September 8, 2007 | 187 | | | 187 |
| October 9, 2007 | 132 | [GSHP Commissioned] | | 132 |
| November 9, 2007 | 328 | | | 328 |
| December 10, 2007 | 1,868 | [GSHP HYD Startup] | | 1,868 |
| January 10, 2008 | 1,626 | 2,094 | | 3,720 |
| TOTAL kWh | 4,318 | 2,094 | | 6,412 |

January through December 2008

| Date Meter Read | Non-Interruptible Household Power | Dual Fuel Econar Geothermal/Seisco Microboiler | Off Peak Hot Water Heat Marathon | Total |
|-------------------|-----------------------------------|--|----------------------------------|---------------|
| February 8, 2008 | 560 | 2,418 | | 2,978 |
| March 8, 2008 | 624 | 3,957 [Anomaly] | | 4,581 |
| April 9, 2008 | 575 | 1,141 | | 1,716 |
| May 8, 2008 | 472 | 309 | | 781 |
| June 9, 2008 | 353 | 1,198 [Anomaly] | [DHW Online] | 1,551 |
| July 10, 2008 | 79 | 263 | 419 | 761 |
| August 9, 2008 | 553 | | | 553 |
| September 8, 2008 | 108 | 185 | 634 | 927 |
| October 8, 2008 | 378 | 208 | 651 | 1,237 |
| November 8, 2008 | 404 | 813 | 548 | 1,765 |
| December 8, 2008 | 421 | 1,802 | 407 | 2,630 |
| January 8, 2009 | 600 | 2,884 | 399 | 3,883 |
| TOTAL kWh | 5,127 | 15,178 | 3,058 | 23,363 |

14,222 kWh

3,919 kWh

January through December 2009

| Date Meter Read | Non-Interruptible Household Power | Dual Fuel Econar Geothermal/Seisco Microboiler | Off Peak Hot Water Heat Marathon | Total |
|-------------------|-----------------------------------|--|----------------------------------|---------------|
| February 11, 2009 | 580 | 3,266 | 406 | 4,252 |
| March 9, 2009 | 400 | 2,225 | 371 | 2,996 |
| April 8, 2009 | 569 | 1,821 | 548 | 2,938 |
| May 8, 2009 | 447 | 939 | 592 | 1,978 |
| June 11, 2009 | 544 | 395 | 761 | 1,700 |
| July 8, 2009 | 524 | 139 | 597 | 1,260 |
| August 8, 2009 | 557 | 22 | 695 | 1, 274 |
| September 8, 2009 | 624 | 114 | 699 | 1,437 |
| October 8, 2009 | 603 | 220 | 671 | 1,494 |
| November 10, 2009 | 960 | 992 | 633 | 2,585 |
| December 8, 2009 | 800 | 1,265 | 573 | 2,638 |
| January 8, 2010 | 1,016 | 2,098 | 513 | 3,627 |
| TOTAL kWh | 7,624 | 13,496 | 7,059 | 28,179 |

14,222 kWh

3,919 kWh

January through December 2010

| Date Meter Read | Non-Interruptible Household Power | Dual Fuel Econar Geothermal/Seisco Microboiler | Off Peak Hot Water Heat Marathon | Total |
|-------------------|-----------------------------------|--|----------------------------------|---------------|
| February 8, 2010 | 852 | 1,995 | 505 | 3,352 |
| March 9, 2010 | 684 | 1,708 | 477 | 2,869 |
| April 9, 2010 | 740 | 1,133 | 605 | 2,478 |
| May 9, 2010 | 698 | 579 | 600 | 1,877 |
| June 9, 2010 | 676 | 176 | 697 | 1,549 |
| July 9, 2010 | 695 | 6 | 711 | 1,412 |
| August 9, 2010 | 755 | 166 | 785 | 1,706 |
| September 9, 2010 | 830 | 284 | 769 | 1,883 |
| October 9, 2010 | 664 | 310 | 719 | 1,693 |
| November 9, 2010 | 798 | 611 | 738 | 2,147 |
| December 9, 2010 | 756 | 1,524 | 601 | 2,881 |
| January 9, 2011 | 745 | 2,262 | 478 | 3,485 |
| TOTAL kWh | 8,893 | 10,754 | 7,685 | 27,332 |

14,222 kWh

3,919 kWh

January through December 2011

| Date Meter Read | Non-Interruptible Household Power | Dual Fuel Econar Geothermal/Seisco Microboiler | Off Peak Hot Water Heat Marathon | Total |
|-------------------|-----------------------------------|--|----------------------------------|---------------|
| February 9, 2011 | 834 | 1,982 [Offline 10 Days] | 490 | 3,306 |
| March 9, 2011 | 684 | 2,203 | 589 | 3,476 |
| April 9, 2011 | 661 | 956 | 601 | 2,218 |
| May 13, 2011 | 746 | 586 | 724 | 2,056 |
| June 9, 2011 | 663 | 0 | 674 | 1,337 |
| July 9, 2011 | 848 | 152 | 779 | 1,779 |
| August 9, 2011 | 940 | 460 | 756 | 2,156 |
| September 9, 2011 | 764 | 234 [IDF LP Upgrade] | 708 | 1,706 |
| October 9, 2011 | 695 | 0 | 707 | 1,402 |
| November 9, 2011 | 764 | 329 | 676 | 1,769 |
| December 9, 2011 | 814 | 997 | 586 | 2,397 |
| January 9, 2012 | 862 | 1,359 | 580 | 2,801 |
| TOTAL kWh | 9,275 | 9,258 | 7,870 | 26,403 |

14,222 kWh

3,919 kWh

January through December 2012

| Date Meter Read | Non-Interruptible Household Power | Dual Fuel Econar Geothermal/Seisco Microboiler | Off Peak Hot Water Heat Marathon | Total |
|-------------------|-----------------------------------|--|----------------------------------|---------------|
| February 10, 2012 | 876 | 1,370 | 462 | 2,717 |
| March 11, 2012 | 758 | 1,166 | 536 | 2,460 |
| April 10, 2012 | 767 | 547 | 625 | 1,939 |
| May 9, 2012 | 691 | 472 | 600 | 1,763 |
| June 9, 2012 | 760 | 4 | 741 | 1,505 |
| July 8, 2012 | 817 | 338 | 726 | 1,881 |
| August 9, 2012 | 986 | 707 | 902 | 2,595 |
| September 9, 2012 | 847 | 368 | 759 | 1,974 |
| October 10, 2012 | 765 | 32 | 833 | 1,630 |
| November 11, 2012 | 869 | 494 | 803 | 2,166 |
| December 9, 2012 | 816 | 892 | 535 | 1,513 |
| January 10, 2013 | 948 | 1,579 | 495 | 3,022 |
| TOTAL kWh | 9,900 | 7,969 | 8,017 | 25,886 |

14,222 kWh

3,919 kWh

By comparison, the equivalent amount of kWh usage for 100% *conventional* electric heating, cooling & domestic hot water would be **54,000 kWh Annually!**

END



Geothermal Design & Application Study

Clair Nelson Intermodal Transportation Center
Finland, MN
16 Ton ColdClimate Hydronic Heat Only GSHP Application

PRESENTER:
Mark Sakry, CGD
Northern GroundSource Inc.
www.NorthernGroundSource.com



Schematic Design
Partners & Sirny
July 2005

"Finland Community Center" Model View



Community Center Conceptual Site Plan



Community Center Architectural Drawings

CODE BASE LWE

| COMPONENT LOAD SUMMARY | | | |
|------------------------|-------------------|-----------------|-------------------------------|
| Building Name: | Ferland | Date: | November 13, 2008 |
| Owner's Name: | Ferland | Builder's Name: | |
| Property Address: | Ferland, MN 55803 | Weather Site: | DJAB, MN |
| | | File Name: | 06.11.13 Revised Baseline.rtg |

| HEATING SEASON (MMBtu/yr) | |
|---------------------------|--------------|
| Ceilings/Floors | 45.6 |
| Roof/Brand Joints | 0.0 |
| Above Grade Walls | 61.2 |
| Foundation Walls | 0.0 |
| Doors | 6.2 |
| Windows/Skylights | 30.7 |
| Frame Floors | 0.0 |
| Crawl Space/Unf. Bmnt | 0.0 |
| Slab Floors | 49.4 |
| Infiltration | 50.6 |
| Mechanical Ventilation | 7.4 |
| Ducts | 8.3 |
| Active Solar | 0.0 |
| Surpace | 0.0 |
| Internal Gains | -48.6 |
| Total | 206.7 |

Heat Loss Calculation Based on Conventional "Code" Envelope

← 206,700 BTUH

| COOLING SEASON (MMBtu/yr) | |
|---------------------------|------------|
| Ceilings/Floors | 0.3 |
| Roof/Brand Joints | 0.0 |
| Above Grade Walls | -1.2 |
| Foundation Walls | 0.0 |
| Doors | -0.5 |
| Windows/Skylights | 6.3 |
| Frame Floors | 0.0 |
| Crawl Space/Unf. Bmnt | 0.0 |
| Slab Floors | -10.6 |
| Infiltration | -3.8 |
| Mechanical Ventilation | -0.5 |
| Ducts | 0.4 |
| Active Solar | 0.0 |
| Surpace | 0.0 |
| Internal Gains | 24.6 |
| Whole House Ventilation | -6.2 |
| Total | 0.8 |

(20 Ton ColdClimate GSHP Requirement)

RESDesign - Residential Energy Analysis Software v12.42
 This information does not constitute any warranty of energy cost or savings.
 © 1985-2007 Architectural Energy Corporation, Boulder, Colorado.

| COMPONENT LOAD SUMMARY | | | |
|------------------------|-------------------|-----------------|----------------------|
| Building Name: | Ferland | Date: | November 13, 2008 |
| Owner's Name: | Ferland | Builder's Name: | |
| Property Address: | Ferland, MN 55803 | Weather Site: | DJAB, MN |
| | | File Name: | 06.11.13 Revised.rtg |

| HEATING SEASON (MMBtu/yr) | |
|---------------------------|--------------|
| Ceilings/Floors | 26.8 |
| Roof/Brand Joints | 0.0 |
| Above Grade Walls | 38.0 |
| Foundation Walls | 0.0 |
| Doors | 6.2 |
| Windows/Skylights | 20.4 |
| Frame Floors | 0.0 |
| Crawl Space/Unf. Bmnt | 0.0 |
| Slab Floors | 35.2 |
| Infiltration | 40.5 |
| Mechanical Ventilation | 7.4 |
| Ducts | 4.9 |
| Active Solar | 0.0 |
| Surpace | 0.0 |
| Internal Gains | -47.7 |
| Total | 122.7 |

Heat Loss Calculation Based on Improved "European" Envelope

← (40% LESS THAN ENVELOPE)

122,700 BTUH

| COOLING SEASON (MMBtu/yr) | |
|---------------------------|-------------|
| Ceilings/Floors | 0.1 |
| Roof/Brand Joints | 0.0 |
| Above Grade Walls | -0.8 |
| Foundation Walls | 0.0 |
| Doors | -0.6 |
| Windows/Skylights | 3.7 |
| Frame Floors | 0.0 |
| Crawl Space/Unf. Bmnt | 0.0 |
| Slab Floors | -6.4 |
| Infiltration | -2.3 |
| Mechanical Ventilation | -0.5 |
| Ducts | 0.5 |
| Active Solar | 0.0 |
| Surpace | 0.0 |
| Internal Gains | 24.6 |
| Whole House Ventilation | -7.3 |
| Total | 13.3 |

(14 Ton ColdClimate GSHP Requirement)

RESDesign - Residential Energy Analysis Software v12.42
 This information does not constitute any warranty of energy cost or savings.
 © 1985-2007 Architectural Energy Corporation, Boulder, Colorado.

Architect's Load Summary Comparisons

Prepared By:

Northern GroundSource Inc.
 1558 Stone Lt, Bridge Rd.
 Brimson, MN 55602-6032
 Phone: 218-848-2869

Prepared For:

Crystal Bay Township
 P.O. Box A
 Finland, MN 55603
 Phone: 218-353-0300

| | | | | | | | | | |
|-----------------------------------|--------|-------------|-------|-------------------|------|-------------|--|--------------|--|
| Approx. Air Changes / hr | 5.2 | Zone Length | | Zone Width | | Zone Height | | Total Cu. Ft | |
| Air Infiltration Rate (ACH) | 4.83 | | | | | | | | |
| Approx. Zone Volume in Cubic Feet | 97.77 | | 97.77 | | 6.33 | | | 146,519 | |
| Approx. Zone Area in Square Feet | 37.77 | | 37.77 | | | | | 3,358 | |
| Approx. Exposed Wall Area in Sq | 295.06 | | | | 6.33 | | | 5,994 | |
| Indoor Dry-Bulb Design Temperat | 69 | Degree F. | | Window Area | | | | 835 | |
| Outdoor Dry-Bulb Design Tempe | -32 | Degree F. | | Less Door Area | | | | 300 | |
| Design Temperature Difference: | 100 | | | Actual Wall Area: | | | | 5,199 | |

| Structural Element | Structural Element Description | Area [Sq. Ft.] | Element U-Value | Temperature Difference | Total BTUH |
|---------------------------------|---|---|--|----------------------------------|----------------|
| Above Grade Ext. Wall Info | 2 x 4 (R-13) (R-44) (R-13) | 2,439 | 0.0227 | 100 | 5,677 |
| Window Information | Single Pane Double Pane Double with Storm Triple Glazed | 095 | 0.5500 0.4001 0.2682 0.2900 | 100 | 21545 |
| Exterior Door Information | Solid-Core Wood 1-3/4" 24 ga. Steel 1-3/4" 18 ga. Steel Double with Storm | 100 | 0.2525 0.1688 0.2257 0.6000 | 100 | 1688 |
| Floor / Ceiling Information | R-98 R-46 R-43 R-44 R-88 | 1,558 | 0.0257 0.0244 0.0237 0.0223 0.0426 | 100 | 9,948 |
| Above Grade Exposed Floor | 2 x 8 (R-24) 2 x 10 (R-24) 2 x 12 (R-32) Other Slab on Grade | 1,558 | 0.0468 0.0246 0.0295 0.0000 0.0553 | 100 | 31,550 |
| Below Grade Structural Elements | Structural Element Description <td>Area [Sq. Ft.] <td colspan="3">BTUH Loss Factor</td> </td> | Area [Sq. Ft.] <td colspan="3">BTUH Loss Factor</td> | BTUH Loss Factor | | |
| | Floor | | 3.00 | \$/BTUH per Sq. Ft. | 0 |
| | Walls | | 6.00 | BTUH per Sq. Ft. | 0 |
| Air Losses | Air Loss Description <td>Air CFM <td>Loss Factor <td>Temperature Difference <td></td> </td></td></td> | Air CFM <td>Loss Factor <td>Temperature Difference <td></td> </td></td> | Loss Factor <td>Temperature Difference <td></td> </td> | Temperature Difference <td></td> | |
| | Infiltration | 409 | 11 | 100 | 53,029 |
| | Ventilation & Make-Up | 150 | 11 | 100 | 16,500 |
| Duct Loss | Is Ductwork in an unconditioned space | Yes / No | HL Factor | Subtotal | 147,977 |
| | | No | 0.00 | 147,977 | 0 |
| Total Heat Lo: | | | | | 147,977 |

(- Indicates inside and outside air film is calculated in U-value)
 (U-value x H / R-value x (BTUH / Sq. Ft. / degree F. Td)
 (Air loss factor x BTUH / CFM / degree F. Td) 147,977 BTUH

Northern GroundSource Calculated Loads

Manual J Calculations Queried for Unique Location

Considered "Embarrass Effect"

Adjusted Design Temperature Difference (ΔT) to 100°F Between Indoor and Outdoor Conditions

= 147,977 BTUH

= 16 Ton ColdClimate GSHP

GeoSense Data Input

| Prepared For: | | Prepared By: | |
|--|----------|---|-----------------------------------|
| Finland Community Center County Road 7 Finland, MN 55003 14.0 T GeoSource Vans 2 Plus in LP | | Northern GroundSource Inc. 1550 Stone Lk. Bridge Rd. Brainerd, MN 55002-6032 218.845.2009 Prepared On: 8/24/11 1:54 PM | |
| Region (1-6): | 1 | Basin: US | Loop Type: 2-3 T 404 T Earth Loop |
| Heating Estimate Design Data | | | |
| Estimated BTU/Hr Heat Loss | 147,977 | 147,977 | |
| Heat Pump BTU/Hr Output | 139,200 | 128,072 | |
| Number of Aux/HI Suggested | 3 | 7 | |
| Heat Pump C.O.P. | 3.70 | 3.70 | |
| Overall H.P. Heating System C.O.P. | 3.66 | 3.66 | |
| Heating Degree Days | 9,789 | 9,789 | |
| Temperature Difference | 130 | 130 | |
| Correction Factor | 0.80 | 0.80 | |
| KWH Rate for Heat Pump | \$0.087 | \$0.087 | |
| KWH Rate For Aux. Electric Heat | \$0.087 | \$0.087 | |
| KWH Rate for Furnace Fan | \$0.087 | \$0.087 | |
| Conventional Source Table | | | |
| | Units | Efficiency | Cost |
| 1 Electric (Radiant) | KWH | 100% | \$0.087 |
| 2 Electric (Forced Air) | KWH | 100% | \$0.087 |
| 3 Fuel Oil | Gallon | 80% | \$3.890 |
| 4 L.P. Gas | Gallon | 90% | \$2.990 |
| 5 Natural Gas | Therm | 90% | \$1.150 |
| Conventional Source Selection | | | |
| | Heating | Cost | |
| Number of Other Energy Sources | 4 | 1 | |
| Other Source Efficiency | 90% | 100% | |
| Other Source Cost or Rate | \$2.990 | \$0.087 | |
| Cooling Estimate Design Data | | | |
| Estimated BTU/Hr Heat Gain | 81,367 | 81,367 | BTU/Hr |
| Heat Pump AC BTU/Hr Capacity | 128,000 | 81,367 | BTU/Hr |
| Cooling System E.E.R. | 21.2 | 10.0 | E.E.R. |
| Cooling Degree Days | 261 | 261 | Days |
| Temperature Difference | 20 | 20 | Degree F. |
| Summer or AC Electric Rate | \$0.107 | \$0.107 | \$/KWH |
| Drill Estimate Demand Data | | | |
| | Quantity | Units | |
| Total Number of People in the Household | 4 | People | |
| Average Number of Gallons per Person per Day | 75 | Gallons | |
| Average Number of Gallons Needed per Day | 80 | Gallons/Day | |
| Expected Average Leaving Water Temperature | 130 | Degree F. | |
| Expected Average Entering Water Temperature | 45 | Degree F. | |
| Average Overall Water Temperature Difference | 85 | Degree F. | |

Northern GroundSource GSHP Design Input

ColdClimate GSHP Capacity
to Peak Heating Load

Considered "Embarrass Effect"

Adjusted Design Temperature
Difference (ΔT) to 100°F
Between Indoor and Outdoor
Conditions

Considered F/A Heat/Cool

Considered 98% Geothermal
with Auxiliary RH

= **147,977 BTUH**

= **14 Ton 3HT/2CL F/A GSHP**

Northern GroundSource GSHP Design Input

ColdClimate GSHP Capacity
to Peak Heating Load

Considered "Embarrass Effect"


Adjusted Design Temperature
Difference (ΔT) to 100°F
Between Indoor and Outdoor
Conditions

Considered F/A Heat/Cool

Considered 98% Geothermal
with Auxiliary RH

= **147,977 BTUH**

= **14 Ton 3HT/2CL F/A GSHP**



Estimated Annual Operating Costs For Finland Community Center

14T 3HT/2CL F/A GSHP SYSTEM

| Estimated Energy Consumption | | | Heating | | Cooling | DHW | | Estimated Annual Totals | |
|-------------------------------------|--------------------------|------------|---------|-----------|---------|-------|-----------|-------------------------|-----------|
| | | | w/o | w/Desuper | | w/o | w/Desuper | w/o Desuper | w/Desuper |
| ECONAR GeoSource Heat Pump | Kwh/yr | | 21,900 | 21,716 | 1,157 | | 1,027 | 23,057 | 23,900 |
| Auxiliary Ht and Electric Water Htr | Kwh/yr | | 459 | 1,140 | | | 706 | 459 | 1,846 |
| Other Fuel Source | 1. Electric (Radiant) | Kwh/yr | | | 2,454 | 5,225 | | 5,225 | |
| | 2. Electric (Forced Air) | Kwh/yr | | | | | | 2,454 | |
| | 3. Fuel Oil | Gallons/yr | | | | | | | |
| | 4. LP Gas | Gallons/yr | 3,377 | | | | 3,377 | | |
| | 5. Natural Gas | Therms/yr | | | | | | | |

25,746kWh


[Includes Cooling!]

| Estimated Operating Costs | | | Heating | | Cooling | DHW | | Estimated Annual Totals | |
|-------------------------------------|----------------------------|--|------------|------------|----------|----------|------------|-------------------------|------------|
| | | | w/o | w/Desuper | | w/o | w/Desuper | w/o Desuper | w/Desuper |
| ECONAR GeoSource Heat Pump | | | \$1,905.29 | \$1,889.28 | \$123.84 | | \$89.36 | \$2,029.13 | \$2,102.48 |
| Auxiliary Ht and Electric Water Htr | | | \$39.93 | \$99.17 | | | \$61.44 | \$39.93 | \$160.61 |
| Other Fuel Source | 1. Electric (Radiant) | | | | \$262.54 | \$454.56 | | \$454.56 | |
| | 2. Electric (Forced Air) * | | | | | | | \$262.54 | |
| | 3. Fuel Oil * | | | | | | | | |
| | 4. LP Gas * | | \$9,038.65 | | | | \$9,038.65 | | |
| | 5. Natural Gas * | | | | | | | | |

| Estimated Cost Savings | | | Heating | | Cooling | DHW | | Estimated Annual Totals | |
|---------------------------------------|--|--|-------------------|-------------------|-----------------|---------------|-----------------|-------------------------|-------------------|
| | | | w/o | w/Desuper | | w/o | w/Desuper | w/o Desuper | w/Desuper |
| Conventional Heating, Cooling and DHW | | | \$9,038.65 | \$9,038.65 | \$262.54 | \$454.56 | \$454.56 | \$9,755.74 | \$9,755.74 |
| ECONAR GeoSource Heat Pump | | | \$1,945.22 | \$1,968.45 | \$123.84 | \$454.56 | \$150.80 | \$2,523.62 | \$2,263.09 |
| Savings Using ECONAR Heat Pump | | | \$7,093.42 | \$7,050.19 | \$138.70 | \$0.00 | \$303.76 | \$7,232.12 | \$7,492.65 |


| | w/o | w/Desuper | |
|--|-------|-----------|---|
| On a yearly basis, this means the heat pump alone should cover | 99.4% | 98.6% | of the total space heating load annually. |
| Auxiliary heat shouldn't be needed until the actual outdoor temperature falls to | -24 | -16 | degrees Fahrenheit. |
| The heat gain to Heat Pump cooling capacity ratio is | 1.6 | 1.6 | (This ratio should be between 1 and 2) |
| On a yearly basis, the heat pump alone should also cover | 0% | 86% | of the total DHW water heating load annually. |

* = includes cost of operating the boiler



- ☞ Note – Always use copper pipe on the hydronic side.
- ☞ Note – Conceptual drawing only. Check local codes and use proper plumbing procedures.

Hydronic "Heat Only" GSHP System



Hydronic Heat/Cool GSHP System

GeoSense Data Input

| | | | |
|---|------------------------|--|------------|
| Prepared For: | | Prepared By: | |
| Finland Community Center County Road 7 Finland, MN 55003 18.0 T Geosystems Ultra HYD w/ LP | | Northern GroundSource Inc. 1558 Stone Lk. Bridge Rd. Brimson, MN 55002-8032 218-843-2888 Prepared On: 10/13/11 9:34 AM | |
| Region (T 16): | 1 | State: | MN |
| Loop Type: | 2.3 T <10 T Earth Loop | | |
| Heating Estimate Design Data | | | |
| Estimated BTU/Hr Heat Loss | 147,977 | wt/Designer | 547,977 |
| Heat Pump BTU/Hr Output | 184,100 | | 140,250 |
| Number of kW of Aux/HT Suggested | 0 | | 3 |
| Heat Pump C.O.P. | 3.70 | | 3.70 |
| Overall H.P. Heating System C.O.P. | 3.70 | | 3.66 |
| Heating Degree Days | 9,789 | | 9,789 |
| Temperature Difference | 100 | | 100 |
| Correction Factor | 0.80 | | 0.80 |
| KWH Rate for Heat Pump | \$0.087 | | \$0.087 |
| KWH Rate For Aux. Electric Heat | \$0.087 | | \$0.087 |
| KWH Rate for Furnace Fan | \$0.087 | | \$0.087 |
| Conventional Source Table | | | |
| | | Units | Efficiency |
| 1 | Electric (Radiant) | KWH | 100% |
| 2 | Electric (Forced Air) | KWH | 100% |
| 3 | Fuel Oil | Gallon | 80% |
| 4 | L.P. Gas | Gallon | 90% |
| 5 | Natural Gas | Therm | 90% |
| Conventional Source Selection | | | |
| | | Heating | Drill |
| Number of Other Energy Source | | 4 | 1 |
| Other Source Efficiency | | 90% | 100% |
| Other Source Cost or Rate | | \$2.090 | \$0.087 |
| Cooling Estimate Design Data | | | |
| Estimated BTU/Hr Heat Gain | 0 | Heat Pump | 0 |
| Heat Pump A/C BTU/Hr Capacity | 0 | Conventional | 0 |
| Cooling System E.E.R. | 21.2 | Units | 0 |
| Cooling Degree Days | 261 | | 0 |
| Temperature Difference | 20 | | 20 |
| Summer or A/C Electric Rate | \$0.107 | | \$0.107 |
| Drill Estimate Demand Data | | | |
| | Quantity | Units | |
| Total Number of People in the Household | 4 | People | |
| Average Number of Gallons per Person per Day | 15 | Gallons | |
| Average Number of Gallons Needed per Day | 60 | Gallons/Day | |
| Expected Average Leaving Water Temperature | 130 | Degree F. | |
| Expected Average Entering Water Temperature | 45 | Degree F. | |
| Average Overall Water Temperature Difference | 85 | Degree F. | |

Northern GroundSource GSHP Design Input

ColdClimate GSHP Capacity
to Peak Heating Load

Considered "Embarrass Effect"

Adjusted Design Temperature
Difference (ΔT) to 100°F
Between Indoor and Outdoor
Conditions

Considered HYD "Heat Only"

Considered 100% Geothermal

= **147,977 BTUH**

= **16 Ton HYD HEAT ONLY**

Northern GroundSource GSHP Design Input

ColdClimate GSHP Capacity
to Peak Heating Load

Considered "Embarrass Effect"


Adjusted Design Temperature
Difference (ΔT) to 100°F
Between Indoor and Outdoor
Conditions

Considered HYD "Heat Only"

Considered 100% Geothermal

= **147,977 BTUH**

= **16 Ton HYD HEAT ONLY**



Estimated Annual Operating Costs
For Finland Community Center

16T HYD "HEAT ONLY" GSHP SYSTEM

| Estimated Energy Consumption | | | Heating | | Cooling | DHW | Estimated Annual Totals | |
|-------------------------------------|--------------------------|------------|------------|-----------|---------|-----------|-------------------------|-----------|
| | | | w/o | w/Desuper | | w/Desuper | w/o Desuper | w/Desuper |
| ECONAR GeoSource Heat Pump | Kwh/yr | 22,024 | 21,915 | | | 1,027 | 22,024 | 22,942 |
| Auxiliary Ht and Electric Water Htr | Kwh/yr | | 404 | | | 1,424 | | 1,829 |
| Other Fuel Source | 1. Electric (Radiant) | Kwh/yr | 22,319 kWh | | | 5,225 | 5,225 | |
| | 2. Electric (Forced Air) | Kwh/yr | | | | | | |
| | 3. Fuel Oil | Gallons/yr | | | | | | |
| | 4. LP Gas | Gallons/yr | 3,377 | | | | 3,377 | |
| | 5. Natural Gas | Therms/yr | | | | | | |

23,776kWh

| Estimated Operating Costs | | | Heating | | Cooling | DHW | Estimated Annual Totals | |
|-------------------------------------|----------------------------|------------|------------|-----------|---------|-----------|-------------------------|------------|
| | | | w/o | w/Desuper | | w/Desuper | w/o Desuper | w/Desuper |
| ECONAR GeoSource Heat Pump | | \$1,916.09 | \$1,906.58 | | | \$89.36 | \$1,916.09 | \$1,995.94 |
| Auxiliary Ht and Electric Water Htr | | | \$35.17 | | | \$123.93 | | \$159.10 |
| Other Fuel Source | 1. Electric (Radiant) | | | | | \$454.56 | \$454.56 | |
| | 2. Electric (Forced Air) * | | | | | | | |
| | 3. Fuel Oil * | | | | | | | |
| | 4. LP Gas * | | \$9,038.65 | | | | \$9,038.65 | |
| | 5. Natural Gas * | | | | | | | |

| Estimated Cost Savings | | | Heating | | Cooling | DHW | Estimated Annual Totals | |
|---------------------------------------|--|--|-------------------|-------------------|---------------|---------------|-------------------------|-------------------|
| | | | w/o | w/Desuper | | w/o | w/Desuper | w/o Desuper |
| Conventional Heating, Cooling and DHW | | | \$9,038.65 | \$9,038.65 | \$0.00 | \$454.56 | \$454.56 | \$9,493.20 |
| ECONAR GeoSource Heat Pump | | | \$1,916.09 | \$1,941.75 | \$0.00 | \$454.56 | \$213.29 | \$2,155.04 |
| Savings Using ECONAR Heat Pump | | | \$7,122.56 | \$7,096.89 | \$0.00 | \$0.00 | \$241.27 | \$7,338.17 |

On a yearly basis, this means the heat pump alone should cover Auxiliary heat shouldn't be needed until the actual outdoor temperature falls to

The heat gain to Heat Pump cooling capacity ratio is

On a yearly basis, the heat pump alone should also cover

| w/o | w/Desuper |
|--------|-----------|
| 100.0% | 99.5% |
| -34 | -25 |
| 0.0 | 0.0 |
| 0% | 73% |

of the total space heating load annually degrees Fahrenheit.


(This ratio should be between 1 and 2)

of the total DHW water heating load annually.


NOTE

99.5% GSHP


* includes cost of operating the power



Community Center Proposed GHEX Layout



Community Center Actual GHGX Layout



Community Center Interior Geo-Pipe Routing























IGSHPA STANDARD 3A.11 (1996)

All pipes passing through walls will be **sleeved** and **sealed** with non-hardening caulking material [emphasis added].

Long Sweep Elbows for Pipe Bends!...

Proper pipe sleeve sizing and configuration will make it a lot easier to place geothermal HDPE supply/return header pipes later.



Subheader S/R Slab Penetrations

Clair Nelson Intermodal Transportation Center, Finland, MN




2 X 8T Hydronic
"Heat Only" GSHP
System Served by
Integrated 2 X 8T
Horizontal Slinky
GHEX.

Heats Approximately
10,000 sq' Radiant
Slab with NO Backup
or Auxiliary Heat!

100% HYD "HEAT ONLY" GSHP System

Annual CO2 Emmissions by Technology



Heating

High Capacity Runtime 1,883 hrs
Resistance Heat Runtime 26 hrs

Heat Pump Energy Use 22,810 kWh
Resistance Heat Energy Use 71 kWh
Pumping Energy Use 895 kWh

Cooling

High Capacity Runtime 0 hrs

Heat Pump Energy Use 0 kWh
Pumping Energy Use 0 kWh

GSHP Operating Cost Breakdown for Zone Name

Based on the annual power consumption of the system and the price per kilowatt hour in your area the estimated cost to maintain the set points for this zone are as follows:

Heating

HP Operating Cost \$1,596.76
Resistance Heat Operating Cost \$5.02
Pumping Cost \$62.66
Total Cost \$1,664.43

Cooling

HP Operating Cost \$0.00
Pumping Cost \$0.00

Total Cost \$0.00



| System Type | Heating | Cooling | Total | vs. GSHP |
|--------------------------------|-------------|---------|-------------|------------|
| Ground Source Heat Pump (GSHP) | \$1,664.43 | \$0.00 | \$1,664.43 | — |
| RH | \$6,546.33 | \$0.00 | \$6,546.33 | \$4,881.90 |
| Nat Gas | \$4,552.36 | \$0.00 | \$4,552.36 | \$2,887.93 |
| Propane | \$10,052.32 | \$0.00 | \$10,052.32 | \$8,387.89 |

Resistance Heat w/ Central A/C

Installation Cost \$10,000.00

Incentives \$0.00

Actual Cost \$10,000.00

Down Payment \$0.00

Loan Amount \$10,000.00

Loan Interest Rate 0.000%

Loan Term 0 years

Monthly Payment \$0.00
(P&I only)

Fuel Inflation Rate 3.5%

COP 1.00

SFFR 15.00

GSHP

Installation Cost \$52,400.00

Incentives \$11,000.00

Actual Cost \$41,400.00

Down Payment \$0.00

Loan Amount \$41,400.00

Loan Interest Rate 0.000%

Loan Term 0 years

Monthly Payment \$0.00
(P&I only)

Fuel Inflation Rate 3.5%

Avg. COP 3.93

Avg FFR 0.00

Economics: Cost of Ownership

GSHP Savings Overview

Monthly Operating Cost Savings **\$406.82**

Incremental Loan Payment **\$0.00**

Monthly Savings from GSHP **\$406.82**

Total Savings (After 30 Years) **\$220,616.59**

Simple Payback

GSHP Install Cost **\$41,400.00**

Conventional Install Cost **\$10,000.00**

Conventional Operating Cost **\$6,546.33**

GSHP Operating Cost **\$1,664.43**



$\frac{\$31,400.00}{\$4,881.84}$



Simple Payback Period **6.4 years**

January -- December 2011

[GSHP SYSTEM COMMISSIONED : 11/11/2010]

| Metered Month | Meter No. 0101883032 | Meter No. 0107477721 | Meter No. 092804277 Ground Source Heat | Total |
|------------------|-------------------------|-------------------------|--|---------------|
| December 2010 | 720 | 234 | 3,773 | 4,727 |
| January 2011 | 880 | 88 | 3,136 | 4,104 |
| February 2011 | 1,720 | 107 | 2,420 | 4,247 |
| March 2011 | 2,120 | 67 | 2,234 | 4,421 |
| April 2011 | 1,400 | 43 | 1,485 | 2,928 |
| May 2011 | 1,720 | 124 | 804 | 2,648 |
| June 2011 | 1,840 | 93 | 174 | 2,737 |
| July 2011 | 2,240 | 129 | 48 | 2,417 |
| August 2011 | 2,240 | 209 | 45 | 2,494 |
| September 2011 | 2,400 | 251 | 291 | 2,942 |
| October 2011 | 1,720 | 120 | 710 | 2,550 |
| November 2011 | 1,200 | 98 | 1,463 | 2,761 |
| December 2011 | 1,240 | 67 | 2,429 | 3,736 |
| TOTAL kWh | 20,200 | 1,563 | 15,239 | 38,346 |

\$1,011.87
(\$0.066/kWh)

23,776 kWh
\$1,664.43

January -- December 2012

| Metered Month | Meter No. 0101883032 | Meter No. 0107477721 | Meter No. 092804277 Ground Source Heat | Total |
|------------------|-------------------------|-------------------------|--|---------------|
| January 2012 | 1,680 | 105 | 2,799 | 4,584 |
| February 2012 | 1,960 | 235 | 2,014 | 4,209 |
| March 2012 | 1,640 | 136 | 1,179 | 2,955 |
| April 2012 | 1,240 | 118 | 498 | 1,856 |
| May 2012 | 1,840 | 160 | 120 | 2,120 |
| June 2012 | 2,000 | 81 | 42 | 2,123 |
| July 2012 | 2,200 | 94 | 38 | 2,332 |
| August 2012 | 2,320 | 186 | 43 | 2,549 |
| September 2012 | 1,720 | 164 | 27 | 1,911 |
| October 2012 | 1,640 | 183 | 945 | 2,768 |
| November 2012 | 1,960 | 230 | 1,913 | 4,103 |
| December 2012 | 2,080 | 264 | 2,464 | 4,808fs |
| TOTAL kWh | 22,280 | 1,956 | 12,082 | 36,318 |

\$ 802.24
(\$0.066/kWh)

23.776 kWh
\$1,664.43

The Clair Nelson Intermodal Transportation Center
Finland, MN—Construction Completed October 2010





FIN

RESOURCES:

- Minnesota Geothermal Heat Pump Association
www.MNGHPA.org
- Wisconsin Geothermal Association
www.wisgeo.org
- International Ground Source Heat Pump Association
www.igshpa.okstate.edu
- GeoExchange
www.GeoExchange.org
- Association of Energy Engineers
www.aeecenter.org

END